

GLS Geospatial Load Modelling and -Forecasting

Anrich Steyn
GLS Consulting




Presentation Overview

1. Introduction
2. Tools Used
3. Energy Consumption Analysis
4. Geospatial Network Modelling
5. Methodology Overview
6. Problem Statement
7. Load Profile Database
8. Demand Prediction
9. Calibration Process
10. Load Forecast & Future Network
11. Closing Remarks

1. Introduction

- Consumer behaviour has changed – EEDSM, load-shedding, electricity prices, DG
- Growth vs. decline
- Necessitates a renewed look at load modelling and –forecasting



2. Tools Used

Two in-house developed software packages:



Swift

- GIS-based software that performs statistical analysis on utility billing data





Edisan

- GIS-based software for integrated and simplified electrical network planning

3. Energy Consumption Analysis

- Populate the Edisan model with electricity sales data from Swift (energy consumption in kWh)
- Populate the Edisan model with per stand land-use data from Swift
- Loss calculations (system input vs consumer usage)
- Revenue enhancement through, for example, visually identifying unmetered stands
- Tariff analysis (& cost of supply)



4. Geospatial Network Modelling


Working Principle:

- Consumption & land-use of each stand is imported into Edisan model via Swift
- Spatially tie stand to closest LV kiosk/minisub/substation etc. (model dependent)
- Get per-stand consumption, ADMD* and roll up – kiosk- → transformer- → distribution- → substation zones
- Bottom-up approach from stand to substation

Benefits:

- Have the land-use & consumption on a per-stand basis
- No high-level estimation of load class mix in a load area
- Reduces errors in high-level load class mix estimation
- Identify customers affected by outages
- Ability to view composite load profiles at supply points
- Ability to model LV network

*to be discussed



4. Geospatial Network Modelling


Spatial resolution:

- 1) **Substation Zone:** Substation supply area
- 2) **Distribution Zone:** MV switching station supply area
- 3) **Transformer Zone:** MV/LV transformer supply area (minisubs, ground/pole mounted)
- 4) **Kiosk Zone:** LV kiosk supply area


4. Geospatial Network Modelling




4. Geospatial Network Modelling



4. Geospatial Network Modelling




4. Geospatial Network Modelling



4. Geospatial Network Modelling




5. Methodology Overview



6. Problem Statement



- Load data problem – not readily available downstream of HV/MV substation
- Energy consumption data is readily available through Swift database
- Want to ‘predict’ MDs and ADMDs from energy consumption




Area under curve
is $kVAh = \frac{kWh}{PF}$


6. Problem Statement

Energy consumption (known) **How?** → MD & ADMD (unknown)

Research has shown: Consumption -> useful predictor of demand models



(with thanks to Dr. Schalk Heunis)



(with thanks to Dr. Schalk Heunis)

7. Load Profile Database


- Profile types assigned according to land-use imported from Swift into Edisan
- Load profile shapes can be imported, created, and are fully customisable
- Software is flexible, can perform functionality with whatever input it is given
 - Quick and easy testing and verification of different load models can be done

Profile
characteristics



| Profile | Name | LF | PF | Peak | Hour 1 | Hour 2 | Hour 3 | Hour 4 | Hour 5 | Hour 6 |
|---------|-----------------------|------|------|------|--------|--------|--------|--------|--------|--------|
| BUSCOM | 7B-S Warehousing | 0.62 | 0.68 | | 0.35 | 0.35 | 0.35 | 0.35 | 0.35 | |
| BUSCOM | 7D-B Harbour | 0.87 | 0.73 | | 0.79 | 0.77 | 0.75 | 0.78 | 0.86 | |
| BUSCOM | 7D-S Rail | 0.93 | 0.72 | | 0.98 | 0.93 | 0.90 | 0.89 | 0.95 | |
| BUSCOM | 8B Commerce Office | 0.75 | 0.70 | | 0.56 | 0.49 | 0.55 | 0.55 | 0.56 | |
| BUSCOM | 9A Sport | 0.88 | 0.79 | | 0.75 | 0.74 | 0.74 | 0.73 | 0.73 | |
| GOV | 9B Water and Sewerage | 0.88 | 0.75 | | 0.81 | 0.79 | 0.77 | 0.76 | 0.77 | |
| GOV | 9C Hospitals | 0.75 | 0.82 | | 0.57 | 0.56 | 0.55 | 0.56 | 0.58 | |
| EDU | 9C Education | 0.76 | 0.82 | | 0.58 | 0.58 | 0.67 | 0.59 | 0.66 | |
| GOV | 9D Government | 0.73 | 0.83 | | 0.58 | 0.57 | 0.56 | 0.56 | 0.58 | |
| FLAT | Hostel 4_6 | 0.52 | 1.00 | | 0.26 | 0.23 | 0.23 | 0.23 | 0.27 | |
| RES500 | RurRes | 0.51 | 1.00 | | 0.29 | 0.26 | 0.24 | 0.26 | 0.30 | |
| RES1000 | Township 5_6 | 0.52 | 1.00 | | 0.26 | 0.23 | 0.22 | 0.22 | 0.26 | |
| RES1500 | UrbEst 10h+ | 0.74 | 1.00 | | 0.54 | 0.51 | 0.50 | 0.50 | 0.51 | |
| RES2000 | UrbRes 7L_7h | 0.58 | 1.00 | | 0.31 | 0.26 | 0.24 | 0.24 | 0.28 | |
| RES9999 | UrbTwn 7L_8h | 0.71 | 1.00 | | 0.49 | 0.45 | 0.44 | 0.44 | 0.46 | |

Profile shape



7. Load Profile Database


- Profiles normalized with 1 p.u. peak values and do not assume absolute kVA values
 - Same profile shape as national standard assumed, but not necessarily same amplitude
 - Peak value is **calculated** in relation to **actual** consumption data

Profile
characteristics



| Profile | Name | LF | PF | Peak | Hour 1 | Hour 2 | Hour 3 | Hour 4 | Hour 5 | Hour 6 |
|---------|-----------------------|------|------|------|--------|--------|--------|--------|--------|--------|
| BUSCOM | 7B-S Warehousing | 0.62 | 0.68 | | 0.35 | 0.35 | 0.35 | 0.35 | 0.35 | |
| BUSCOM | 7D-B Harbour | 0.87 | 0.73 | | 0.79 | 0.77 | 0.75 | 0.78 | 0.86 | |
| BUSCOM | 7D-S Rail | 0.93 | 0.72 | | 0.98 | 0.93 | 0.90 | 0.89 | 0.95 | |
| BUSCOM | 8B Commerce Office | 0.75 | 0.70 | | 0.56 | 0.49 | 0.55 | 0.55 | 0.56 | |
| BUSCOM | 9A Sport | 0.88 | 0.79 | | 0.75 | 0.74 | 0.74 | 0.73 | 0.73 | |
| GOV | 9B Water and Sewerage | 0.88 | 0.75 | | 0.81 | 0.79 | 0.77 | 0.76 | 0.77 | |
| GOV | 9C Hospitals | 0.75 | 0.82 | | 0.57 | 0.56 | 0.55 | 0.56 | 0.58 | |
| EDU | 9C Education | 0.76 | 0.82 | | 0.58 | 0.58 | 0.67 | 0.59 | 0.66 | |
| GOV | 9D Government | 0.73 | 0.83 | | 0.58 | 0.57 | 0.56 | 0.56 | 0.58 | |
| FLAT | Hostel 4_6 | 0.52 | 1.00 | | 0.26 | 0.23 | 0.23 | 0.23 | 0.27 | |
| RES500 | RurRes | 0.51 | 1.00 | | 0.29 | 0.26 | 0.24 | 0.26 | 0.30 | |
| RES1000 | Township 5_6 | 0.52 | 1.00 | | 0.26 | 0.23 | 0.22 | 0.22 | 0.26 | |
| RES1500 | UrbEst 10h+ | 0.74 | 1.00 | | 0.54 | 0.51 | 0.50 | 0.50 | 0.51 | |
| RES2000 | UrbRes 7L_7h | 0.58 | 1.00 | | 0.31 | 0.26 | 0.24 | 0.24 | 0.28 | |
| RES9999 | UrbTwn 7L_8h | 0.71 | 1.00 | | 0.49 | 0.45 | 0.44 | 0.44 | 0.46 | |

Profile shape



8. Demand Prediction

$$MD_{theoretical} (kVA) = \frac{Consumption_{Swift} (kWh)}{LF \times PF \times 24h}$$

where

$MD_{theoretical}$ → theoretical maximum demand for a stand

LF → aims to provide compensation for using averaged, as opposed to peak consumption

LF, PF → theoretical values assumed from current national standard load shapes

$Consumption_{Swift}$ input can vary:




- **Annual Average Daily** Consumption (initial method tested)
- **Per Month Average Daily** Consumption
- **Peak Month Average Daily** Consumption
- **Statistical distribution of Daily** consumption (reflecting some input variability in demand calculation output)

Or


- Consumption can be considered on a monthly basis, with no averaging

8. Demand Prediction

- Substation-, distribution-, transformer- or kiosk zone profile is a summation of all profiles within zone



8. Demand Prediction



Consumption,
MD, ADMD
breakdown
per load class

Combined-
and per-
class load
profiles

Combined
consumption
and MD
hourly
breakdown

8. Demand Prediction

What about non-domestic users?

- ADMD not a useful metric for non-domestic - rather consumption density (kVA/Ha)
- Non-domestic kVA metering database also imported geospatially via Swift
- Facilitates easy comparison of predicted kVA versus metered kVA


Edisan is an integrated database

- Consolidate various datasets into one geospatial network model
- Future datasets
 - Climate data
 - Solar irradiance data
 - Building footprint shapefiles – commercial & industrial demand density metrics (kVA/Ha)
 - Any other relevant metrics that will aid in studying load behaviour

9. Calibration Process


Error is obviously introduced

- 1) Consumption resolution is per month (and not daily, 30- or even 5-minute)
 - Loss of visibility in the variability of the consumption with increased averaging interval
 - To what extent?
- 2) Making the jump from energy -> demand introduces error (even with high-resolution, accurate consumption data)
 - To what extent?



Sensitivity of load demand to cadence (Sellick & Gaunt, 1996)


(with thanks to Mr. Justice Chihota)



(with thanks to Mr. Justice Chihota)

9. Calibration Process

- 5/30-minute data at HV/MV substation typically available
 - Currently have strategic minisub metering @ specific client for increased downstream visibility
- Use metered data to calibrate downstream loads
- Automatic load scaling functionality in Edisan, can be applied:
 - Per stand
 - Per load class
 - Per kiosk-, transformer-, distribution- or substation zone
 - Per user selection
- Future: Automated curve fitting algorithm
 - Auto calibration within specified set of rules and limits
 - Peak amplitude calibration vs. shape shifting
 - Different customer groupings?



Important:

Capture calibration information to study the relationship between consumption and demand

Load Forecast & Future Network

1. Future loads (load growth pockets)


- Future development geospatial shapefile – **location**, **size**, anticipated **land-use**, priority (**when**) and duration (**how long**)
- Based on SDF, IDP, House Plans etc. - workshopped with town planners & electrical departments
- Growth curve – linear, step, s-curve or custom
- Scenario-based planning between 2 extremes (current situation → saturation)

2. Current loads

- Change in behaviour (stagnation, growth or decline)
- Growth curve – linear, step, s-curve or custom


3. Distributed generation

4. Demand-side management strategies



Load Forecast & Future Network



Existing network




Future (SDF overlay)



| | AADC Scenario5 [kWh] | Demand Zones | Future Demand Zones | Load Factor | Load Factor Category | Adjust Factor | Land Use Category |
|------|----------------------|------------------|---------------------|-------------|----------------------|---------------|-------------------|
| 0.00 | 100.00 | DELTA SUBSTATION | | 0.50 | | | |
| 5.30 | 395.30 | ALPHA SUBSTATION | | 0.50 | | | FARM_AH |
| 4.06 | 254.06 | ALPHA SUBSTATION | | 0.52 | | | EDUCATION |
| 0.10 | 90.10 | ALPHA SUBSTATION | | 0.74 | | | PARKS |



Load Forecast & Future Network



10. Closing Remarks

- Load behaviour needs to be actively studied to keep trend with status quo
- GLS has powerful tools to support load modelling process
- Available data is limited
 - How do we best use the data that we **do** have?
 - How do we go about sourcing the necessary data we need
- The more times we do this, the more data we will have, and the more informed we will be
 - Refinement process
 - Rinse, repeat, learn, adjust

Contact

Hilton Baartman (Director): hilton@gl.s.co.za; 0727153044

Anrich Steyn (Electrical Engineer): anrich@gl.s.co.za; 0764350190

| CONTACT | | |
|---|--|---|
| Contact Details | Postal Address | Street Address |
| Telephone +27 21 8800388 Fax +27 21 8800389 Email info@gl.s.co.za | GLS Consulting (Pty) Ltd PO Box 814 Stellenbosch 7599 South Africa | 13 Elektron St Techno Park Stellenbosch 7600 South Africa 33° 57' 52" S 18° 50' 17" E View Map |