

Inaccurate Billing / Metering CTs and VTs: The Quickest Way to Gain (or Lose) Revenue!

Alexander Dierks; Riaan Louw; Alectrix (Pty) Ltd, alex@alectrix.co.za



• Why is CT and VT Accuracy So Important?

How much **annual revenue** does a utility gain (or lose), if energy consumption for a **10MVA** load is measured with an **0.2% error**?

N\$250,000

Daily energy consumed = 200MWh = (1*16h + ½*8h)*10MVA (Assumption: Full load for 16h/d; Half load for 8h/d)

Annual revenue = N\$125Million = 250d * N\$2,500 1/MWh * 200MWh (Assumption: 250 working days at N\$2.50 1/kWh)

Total Annual Revenue gained/lost = 0.2% * N\$125Million = N\$250,000







SANS 474 / NRS 057

ISBN 978-0-626-22037-2

SANS 474:2009 Edition 1.1 NRS 057:2009 Edition 1.1

SOUTH AFRICAN NATIONAL STANDARD

Code of practice for electricity metering

This national standard is the identical implementation of NRS 057:2009 and is adopted in terms of a Memorandum of Agreement between the Electricity Suppliers Liaison Committee and the SABS Standards Division.

Published by SABS Standards Division 1 Dr Lategan Road Groenkloof ⊠ Private Bag X191 Pretoria 0001 Tel: +27 12 428 7911 Fax: +27 12 344 1568 <u>www.sabs.co.za</u> © SABS





NRS 057 / SANS 474

- Subsequent recalibration of <u>metering system components</u> requires the same full laboratory process as for new components. On-site testing and calibration is acceptable for this purpose as long as the requirements of this code of practise are complied with" (NRS 057:2009; Ch. 4.4.3.4)
- Metering system components" consists of the energy meter(s) as well as the instrument transformer(s).
- Focus of this presentation is the verification of the current transformers (CTs) and voltage transformer (VTs).
- "Recalibration" means 'comparison' or 'verification of accuracy'
- Calibration of inductive CTs IEC 60044-1 / IEC 61869-2: Accuracy verification at 5%, 20%, 100% and 120% I_{nom} for 25% and 100% rated burden.
- Calibration of inductive VTs IEC 60044-2 / IEC 61869-3: Accuracy verification at 80%, 100% and 120% V_{nom} for 25% and 100% rated burden – for all other windings unloaded <u>AND</u> fully loaded.

Customer Load	CT & VT Accuracy	Verification Interval
> 10MVA	class 0.2	5 years
100kVA to 10MVA	class 0.5	10 years
<100kVA	class 1	20 years



Conventional Verification by Primary Injection









Current Transformers (CT)

Ideal Current Transformer





Real Current Transformer (Detailed Electrical Model)



Parameters to determine:

- R_{CT} secondary winding resistance
- Non-linear iron losses: Hysteresis losses R_H, magnetizing inductance L_m and the eddy losses R_{eddy}.
- Ideal transformation ratio N_p/N_s



Accuracy Graph for a Metering / Protection CT

Metering Core:

Protection Core:



• OMICRON CT Analyzer for CT Calibrations

- Portable, compact size and low weight (< 8 kg)</p>
- Field calibration of CTs up to the Class 0.1 accuracy class
- Fast testing time (<1min per core)</p>
- Automatic result assessment as per IEC 60044-1 and IEC61869-2 standards directly after the test
- Simulation and re-assessment with changed CT parameters
- Safety: max. 120 V output voltage
- Reliable: high noise immunity for on-site testing
- Multi-tap CTs can be tested with CT SB2 extension box (up to five taps)





Case Study 1: Post Type CTs



Case Study 1: 66kV CT: 1200A:1A, 10VA, Class 0.2

📔 🟠 HomeC:\Inaccurate billing i	metering CTs and VTs The quickest v	way to gain (or lose) revenue!\Test Files\cx	h-72-meter.xml* - OMICRON C	T Analyzer 🔅 🕐 💶 🗙
New Open Transfer Save Open File	Close Clear results Wiring dia	gram Create report Design report Report		
=	C:\Test Files\cxh-72-meter	r.xml* 😣		
	✓ General			î
통 Advanced CT Test	Company:	Test Company	Manufacturer:	CT Manufacturer
	Country:	Sunshine Country	Туре:	XYZ 123
Preparation	Station:	Test Station	Serial number:	123 456 789
Execution	Feeder:	Test Feeder	Comment:	
V Results	Phase:	Phase 1		
Calculation	Show more			
Accuracy and burden	Test configuration			
	▲ Asset			
	lpn:	1200.000 A 🔻	lsn:	1.000 A 🔻
	Standard:	IEC 60044-1 🔹	Application:	Metering 💌
	Frequency:	50 Hz 🔻	Class:	0.2 💌
	FS:	10.0 💌	Ext Ipn:	120 % 🔻
	4 Burden			
	- buluen			
	Rated burden			
	Extended burden:		Enable rated burden <1 VA:	×
	Burden:	10.000 VA 🔻	cos φ:	0.800
	On anothing building			
	Burden:	10.000 VA 🔻	cos φ:	0.800 🔻
	Lead resistance			-
	Rlead: 🦊	0 mΩ		



Case Study 1: 66kV CT: 1200A:1A, 10VA, Class 0.2

Test device		Date/Time 12/				12/02/2	2/02/2016 09:58						
Test device	CT-Analyzer				Dev	ice s	erial no		MB284K	[
File name	C:\Users\AlexanderDierks\Al	ectrix	Alectrix -	Documents\20)21\Trips\Diç	jital Ses	sions\SAIEE P	resentation	n 2021.02\Test C	ases\cxh-72	-meter.	xml	
Overall assessement	ОК												
Asset													
lpn	1200.0 A		Object					Locat	tion				
Isn	1.0 A		Manuf	acturer				Com	pany				
Rated burden	10.0 VA /0.80		Туре					Coun	itry				
Operating burden	10.0 VA /0.80		Serial	number				Stati	on				
Standard	IEC 60044-1		Core					Feed	ler				
Application	Metering		Тар					Phas	e				
Class	0.2		Option	Optional				IEC-ID					
Frequency	50.0 Hz		Comme	Comment				•					_
Rct max	3.222 Ω	?											
FS	10.0	?											
Ext Ipn	120 %												
Secondary winding resis	tance							Prima	ary winding r	esistanc	e		_
R-meas (25.0 °C)	2.701 Ω		R-mea:	s (25.0 °C)	+Rlead		2.701 Ω	R-me	as				
R-ref (75.0 °C)	3.222 Ω		R-ref (7	(5.0 °C)+RI	ead		3.222 Ω	R-ref	F				
													_
Burden													
Burden			cos op:		Z	—							
V-meas			I-meas										
Excitation													
Ls 0.005587 H L	m 149.925725	Н	Result	s at rated	burden	(10.0	0 VA)	Resu	ilts at opera	ting bu	rden	(10.00 \	VA)
Kr 75.1 %			FS	9.13	FSi	<u> </u>	8.36	FS	9.13	FSi		8.36	ز
Standard	IEC 60044-1		εci (@	FS=10)				εci (@	FS=10)		_		
V-kn 71.820 V I	-kn 0.002 A		Ts	13.360 s	1			Ts	13.360 s				_
Ratio											-		
Turns ratio 1199.3455			Results at rated burden (10.00 VA)				Resu	Its at opera	ting bu	rden	(10.00 \	VA	
εt -0.0545 %			Ratio		12	00.0 :	1.0001	Ratio		12	200.0	: 1.0001	1
Polarity OK ε			0.0124 %	ΔΦ	0.	.42 min	ε	0.0124 %	ΔΦ	0	.42 mir	n	



Case Study 1: 66kV CT: 1200A:1A, 10VA, Class 0.2

Current ratio	o error in %	at % of rated	d current at	rated burder	n (10.00 VA)			
VA/cos ф	1.00 %	5.00 %	10.00 %	20.00 %	50.00 %	100.00 %	120.00 %	200.00 %
10.00/0.80	-0.0158	-0.0087	-0.0049	-0.0007	0.0060	0.0124	0.0142	0.0206
5.00/0.80	0.0171	0.0185	0.0206	0.0223	0.0251	0.0276	0.0283	0.0310
2.50/1.00	0.0466	0.0449	0.0438	0.0431	0.0421	0.0416	0.0415	0.0415
1.25/1.00	0.0482	0.0475	0.0465	0.0461	0.0454	0.0449	0.0447	0.0445
Phase in mir	n at % of rate	ed current at	t rated burd	en (10.00 VA))			
VA/cos ф	1.00 %	5.00 %	10.00 %	20.00 %	50.00 %	100.00 %	120.00 %	200.00 %
10.00/0.80	2.8390	2.0821	1.7067	1.3320	0.8167	0.4245	0.3178	0.0777
5.00/0.80	1.9553	1.5272	1.2975	1.0700	0.7575	0.5115	0.4459	0.2650
2.50/1.00	1.6744	1.4116	1.2626	1.0915	0.8719	0.6916	0.6433	0.5033
1.25/1.00	1.2888	1.1112	1.0123	0.8800	0.7145	0.5804	0.5439	0.4400



Case Study 2: 100A:1A, 10VA, Class 1

Current ratio	error in % at	% of rated c	urrent at rate	d burden (10	.00 VA)			
VA/cos φ	1.00 %	5.00 %	10.00 %	20.00 %	50.00 %	100.00 %	120.00 %	200.00 %
10.00/0.80	-4.3859	-2.2483	-1.7909	-1.4812	-1.1192	-0.8613	-0.7917	-0.5416
5.00/0.80	-2.7831	-0.8220	-0.4963	-0.2643	-0.0588	0.0806	0.1156	0.2126
2.50/1.00	-0.0087	0.6307	0.7460	0.8246	0.8850	0.9092	0.9170	0.9375
1.25/1.00	0.4590	0.8583	0.9540	1.0151	1.0666	1.0871	1.0914	1.1009

Phase in min at % of rated current at rated burden (10.00 VA)

VA/cos φ	1.00 %	5.00 %	10.00 %	20.00 %	50.00 %	100.00 %	120.00 %	200.00 %
10.00/0.80	115.2638	64.1793	53.3167	44.4075	33.6205	24.8930	22.0891	12.3455
5.00/0.80	97.7956	42.6187	35.0336	29.1495	22.6513	18.4887	17.3690	13.6873
2.50/1.00	131.6096	51.9136	41.5340	34.9057	28.6622	24.7641	23.8565	21.4562
1.25/1.00	112.6944	38.9152	28.5927	23.1707	18.6099	16.1587	15.5619	13.9497





Case Study 3: 300:1, 15VA 5P30 Protection Core



E la la	•								

Excitation

Ls	0.003504 H	Lm	61.784285 H	Resul	Its at rated I	ourder	n (15.00 VA)
Kr	89.81 %			ALF	> 38.31	ALFi	37.41
Standard	d	1	EC 61869-2	εci (@	ALF=30)		0.108 %
V-kn	504.755 V	I-kn	0.0306 A	Ts	4.220 s		



Case Study 3: 300:1, 15VA 5P30 Protection Core

Current ratio	error in % at	% of rated o	urrent at rate	d burden (15.	00 VA)			
VA/cos φ	1.00 %	5.00 %	10.00 %	20.00 %	50.00 %	100.00 %	120.00 %	200.00 %
15.00/0.80	-0.9686	-0.4505	-0.3389	-0.2603	-0.1962	-0.1674	-0.1613	-0.1485
7.50/0.80	-0.6677	-0.3179	-0.2321	-0.1768	-0.1274	-0.1045	-0.0999	-0.0899
3.75/1.00	-0.0795	-0.1239	-0.1038	-0.0848	-0.0642	-0.0523	-0.0500	-0.0443
1.88/1.00	-0.0402	-0.0896	-0.0800	-0.0651	-0.0500	-0.0404	-0.0383	-0.0336
Phase in mir	n at % of rate	d current at r	ated burden (15.00 VA)				
VA/cos φ	1.00 %	5.00 %	10.00 %	20.00 %	50.00 %	100.00 %	120.00 %	200.00 %
15.00/0.80	20.2057	7 7440	4 6 4 2 0	0.4007	0.4504	4 75 67	1 6715	1 4051
	29.2007	7.7442	4.6430	3.1307	2.1521	1./56/	1.0/15	1.4951
7.50/0.80	29.2837	7.3543	4.6430	2.8257	1.7791	1.7567	1.8715	1.14951
7.50/0.80 3.75/1.00	29.6845 31.6301	7.3543	4.6430 4.4448 6.4642	3.1307 2.8257 4.3017	2.1521 1.7791 2.7528	1.7567 1.3809 2.1214	1.3037	1.1446





Special Applications: Bushing Type CTs





Special Applications: GIS







Voltage Transformers (VT)

Real Voltage Transformer (Detailed Electrical Model)



Parameters to determine:

- 1) Secondary winding resistance R₁ and R₂
- 2) Short circuit impedances yielding R_p ", X_p ", X_1 and X_2
- 3) Non-linear iron losses $R_{\rm m}$ and $X_{\rm m}$



OMICRON VOTANO 100 for VT Calibrations

- Portable, compact size and low weight (8kg + 7kg)
- Field calibration of VTs up to the Class 0.1 accuracy class
- Software-guided test procedure ensures short testing time (<15min)</p>
- VTs with up to five secondary windings
- Automatic result assessment as per IEC 60044-2 and IEC61869-3 standards directly after the test

High-voltage environment

Safe area

- Simulation and re-assessment with changed VT parameters
- Safety: Local isolation between high voltage and test equipment Double action to start test; Emergency OFF button

1	😭 Home				VOTANO_ABB_1YMP011TJO00	286_21_08_2019_10_12.vta	- OMICRON VOTAN	Ю	☆ 0 _ □ ×
N	ew Open	t Transfer	Save	Close	Clear results Wiring diagram				
1	Advanced VT/CVT te	st	✓ General Company: Country: Station: Feeder: Phase:	Test Utility Country Test SS T2 Red Phase			Manufacturer: Type: Serial number: Comment:	VT Manufacturer XYZ 1YMP011TJO00286 VOTANO 100 Demonstration	
► •	Preparation Execution Results Report		IEC-ID: Test configure Asset Model: Upr:	ration	VT 1/√3 33.0 kV	V V	Standard: TSB:	IEC 60044-2	The second secon
		I.	Frequency: No. of sec. wine Rlead:	dings:	50 Hz 2 0 mΩ	▼ ▼ ▼	Fv: Residual windin	1.2 g: X	•
			la-1n 2a-2n	P/M: Class: Usr: Ratio: Sr:	M 0.5 1/√3 110.0 V 300:1 30 VA	▼ ▼ ▼	cos¢:	0.8	*
		Т	est data loaded	from 'C:\Users\	AlexanderDierks\Alectrix\Alectrix	x - Documents\2022\Trips\\	Webinars\Inaccurate	billing metering CTs and VTs The quickest Zoom 100 %	Start test



			VOTANO Adv	anced VT Test				-				
Company		Test Utility	1									
Company address												
		1						-				
Order number												
	Object				Location							
Manufacturer		VT Manuf	acturer	Company		Test	t Utility					
Туре		XYZ	Z	Country		Co	untry					
Serial number		1YMP011T.	1000286	Station		Te	est SS					
Comment				Feeder								
VOTANO 100 Demons	stration			Phase		Re			Excitat	ion curve		
				IEC-ID						1000		
										1000	.00	
Model			VT	Туре								
Rated primary voltag	ge [V]	3	33000/v3	Serial number								
Applied standard		IE	C 60044-2	Measurement savin	gtime	201						
Rated frequency [Hz]			50.00	Firmware version	2	.10 (
Fv			1.2									
Winding	Rated sec. volt	age [V]	Class	M-Class	Nom. Burden [VA]/c	osφ				100	,00	
1a-1n	110/v3			0.5	30/0.8							
2a-2n	110/v3		3P	n/a	30/0.8							
						_	_					
Overall assessment			ОК				2					
						_	e e					
Winding	w	inding Resist	tance [Ω]		Ratio		/off			10	.00	
1a-1n		0.1914	4	330	00/v3 : 110.0081/v3	3	VS					
2a-2n		0.2956	5	330	00/v3 : 109.9612/v3	-	28					
									/	1	.00	
							0.00	0	01	0.10		10.00
							L		DNAC	eurropt [A]	.10	
									RIVIS			



						Burden					
Winding	Upr	Usr	Freq.	S1	S2	S3	S4	S5	U Tec1	Ratio error	Phase error
	[KA]	[v]	[H2]	[VA]	[VA]	[VA]	[VA]	[VA]	[70]	[%]	[min]
1a-1n	33/v3	110/V3	50	30/0.8					80%	0.0080	-0.50
									100%	0.0073	-0.47
									120%	0.0054	-0.43
				7.5/0.8					80%	0.1688	-0.55
									100%	0.1681	-0.52
									120%	0.1662	-0.49
				30/0.8	30/0.8				80%	-0.0701	-2.15
									100%	-0.0708	-2.12
									120%	-0.0727	-2.09
				7.5/0.8	30/0.8				80%	0.0905	-2.21
									100%	0.0899	-2.18
									120%	0.0879	-2.14
2a-2n	33/v3	110/V3	50		30/0.8				2%	-0.1157	1.04
									5%	-0.0822	1.16
									100%	-0.0353	1.20
									100*Fv%	-0.0372	1.23
					7.5/0.8				2%	0.0878	-0.49
									5%	0.1213	-0.37
									100%	0.1683	-0.33
									100*Fv%	0.1664	-0.30
				30/0.8	30/0.8				2%	-0.1966	-0.91
									5%	-0.1633	-0.80
									100%	-0.1164	-0.76
									100*Fv%	-0.1183	-0.73
				30/0.8	7.5/0.8				2%	0.0067	-2.45
									5%	0.0401	-2.33
									100%	0.0871	-2.29
									100*Fv%	0.0852	-2.26









+						+			
		VOTANO Ad	vanced VT Test			_			
Company	Test	t Utility							
Company address	Test	t Workshop							
						-			
Order number									
	Object			Location					
Manufacturer	VT	Manufacturer	Company	Tes	st Utility				
Туре		JDCF-66W3	Country	c	ountry				
Serial number		14180256	Station	We	orkshop				
Comment			Feeder						
VOTANO Demonstrat	tion		Phase	je 🛛			Excitation curve		
			IEC-ID				100.00		
							100.00		
Model		VT	Туре						
Rated primary voltag	ge [V]	66000/v3	Serial number						
Applied standard		IEC 60044-2	Measurement savi	ngtime 2019					
Rated frequency [Hz]		50.00	Firmware version	2.10 (
Fv		1.2							
Winding	Rated sec. voltage [\	/] Class	M-Class	Nom. Burden [VA]/cosφ					
1a-1n	110/√3		0.2	100/0.8			10.00		
2a-2n	110/√3	3P	n/a	100/0.8			10.00		
0					5				
Overall assessment		Failed			e				
		- R [0]		D-at-	tag				
winding 1-1-	Windin	g Resistance [1]		Katio					
1a-1n 2a-2a		0.0278	66	000/03 : 110.0207/03	W				
Za-Zn		0.0496		000/05 : 109.9546/05	ж				
							1.00		
					0.01	0	.10	1.00	10.00
							0.10		
							RMS current [A]		



overview of ratio er	rors and ph	ase displac	ements							
					Burden					
	Upr	Usr	S1	\$2	S3	S4	S5	U	Ratio error	Phase erro
Winding	[1]	[V]	[VA]	[VA]	[VA]	[VA]	[VA]	[%]	[%]	[min]
1a-1n	66/v3	110/v3	100/0.8					80%	0.0520	-6.1
								100%	0.0188	-6.0
								120%	-0.1629	-5.4
			25/0.8					80%	0.2027	-3.
								100%	0.1690	-3.
								120%	-0.0127	-3.0
			100/0.8	100/0.8				80%	-0.0850	-10.4
								100%	-0.1175	-10.3
								120%	-0.2994	-9.3
			25/0.8	100/0.8				80%	0.0654	-8.0
								100%	0.0324	-7.9
								120%	-0.1494	-7.3
2a-2n	66/v3	110/v3		100/0.8				2%	-0.1275	-6.8
								5%	-0.0840	-6.9
								100%	-0.0592	-6.4
								120%	-0.2426	-5.4
				25/0.8				2%	0.0774	-4.2
								5%	0.1210	-3.9
								100%	0.1453	-3.8
								120%	-0.0381	-2.8
			100/0.8	100/0.8				2%	-0.2692	-11.3
								5%	-0.2257	-11.0
								100%	-0.2002	-10.9
								120%	-0.3837	-9.9
			100/0.8	25/0.8				2%	-0.0645	-8.1
								5%	-0.0210	-8.4
								100%	0.0040	-8.3
								120%	 0 1796	7

Winding 1: Class 0.2







Certifications

Certified Accuracy of Calibration Equipment

Physikalisch-Technische Bundesanstalt



Seite 3 zum Kalibrierschein vom 2005-12-02, Kalibrierzeichen: 3403 PTB 05 Page 3 of calibration certificate of 2005-12-02, calibration mark: 3403 PTB 05

5. Messergebniss Messurement results

In den folgenden Tabellen werden die Strommessabweichungen und Fehlwinkel bei Bemessungsübersetzungen in Abhängigkeit von der Bebürdung und dem Messpunkt angegeben. (ICE 60044-1).

Current errors and phase displacement indicated in the following tables are expressed as functions of the corresponding test point and rated ratio.(ICE 60044-1).

Sekundäre Bemessungsstromstärke (rated secondary current)	5A und 1A (and) 50 Hz und 60Hz (and)			
Frequenz (frequency)				
Primäre Bemessungsstromstärke (rated primary current) in A	Bürde (burden)	Prüfpunkt (test point)	ει	δι
5 A – 5000 A	0-10 VA	200 % - 1 %	0,02 %	1,0 min.



Seite 4 zum Kalibrierschein vom 2016-04-11, Kalibrierzeichen: 21106 PTB 16 / 21107 PTB 16 Page 4 of the Calibration Certificate dated 2016-04-11, calibration mark: 21106 PTB 16 / 21107 PTB 16

Tabelle 2

-	4	10	0	
а	ø	e	6	

Spannungswandler, Klasse 0,1, Betriebsbürde 50 VA Voltage transformer, class 0,1, rated burden 50 VA

			110 kV/√3	/ 100 V/√3			
Bürde Burden	Messpunkt Test point	Referenz Reference		Ablesung Displayed value		Differenz Difference	
	in %	ε _u in %	${\cal S}_{u}$ in '	ε _υ in %	δ_u in '	ິຍ in %	δ_{u} in '
Leerlauf No burden	120	0,042	-0,6 -0.8	0,060	-1,1 -1.3	0,018 0.016	-0,5 -0,5
	80	0,048	-0,9	0,062	-1,3	0,015	-0,5
	60	0,040	-0,9	0,054	-1,3	0,014	-0,4
	40	0,022	-0,7	0,030	-1,1	0,008	-0,4
	20	-0,021	-0,1	-0,024	-0,4	-0,004	-0,4
	10	-0,070	0,8	-0,086	0,5	-0,016	-0,3
	5	-0,126	1,6	-0,117	0,9	0,009	-0,7



Summary

- Regular and accurate verification of instrument transformers, as required by the Code of Electricity Metering, can conveniently be conducted in the field by utilizing a modelling verification, instead of following a conventional primary injection calibration.
- The modelling approach consists of accurately characterizing the electrical model of a CT (or VT), then calculating the amplitude and phase angle accuracy of the device under test for the required burden 'connected' to the CT (or VT) and 'injecting' the required primary current (or primary voltage).
- Calibration of inductive CTs IEC 60044-1 / IEC 61869-2: Accuracy verification at 5%, 20%, 100% and 120% I_{nom} for 25% and 100% rated burden.
- Calibration of inductive VTs IEC 60044-2 / IEC 61869-3: Accuracy verification at 80%, 100% and 120% V_{nom} for 25% and 100% rated burden for all other windings unloaded <u>AND</u> fully loaded.
- Case studies for various metering and protection CTs (and VTs) with both passed and failed results have been presented and results discussed.
- The PTB (and other certification institutes) have certified the accuracy of the modelling verification approach of instrument transformers.

• Thank You for Your Attention!



